

Office of the Station Officer,  
Fire and Rescue Station,  
Thiruvananthapuram - 01  
Dated: 11.05.2018

No. C-538/14

**MINIMUM FIRE SAFETY CERTIFICATE**

As per the request of The Mother Superior, St. Shanthal CBSE School, Malamughal, Thiruvananthapuram Vide Letter Dated 11.05.2018, I have inspected the fire fighting arrangements provided in the Five storied Educational Building with a height of 12.30 M, in Survey number 412/44, 412/6, in Peroorkkada village, Thiruvananthapuram Corporation, and found the following arrangements.

1. Fire Extinguisher
2. Hose Reel
3. Down Comer
4. Sprinkler System (Basement)
5. Booster Pump 900 Lpm
6. Fire Brigade Inlet
7. Over Head water Tank 25000Ltrs capacity
- 8.

The above arrangements were tested and were found working satisfactorily at the time of Inspection.



*[Handwritten Signature]*

Station Officer,  
Fire & Rescue Station,  
Thiruvananthapuram.

*[Handwritten Signature]*

**MANAGER**  
ST. SHANTAL ENGLISH MEDIUM SCHOOL  
MALAMUKAL, P.B. NO. 2813  
THIRUVANANTHAPURAM-695 013



*[Handwritten Signature]*

**PRINCIPAL**  
ST. SHANTAL ENGLISH MEDIUM SCHOOL  
MALAMUKAL, P.B. NO. 2813  
THIRUVANANTHAPURAM-695 013